


NRC Lessons Learned

**Ray Lorson
Chief, Plant Support Branch 1
Region 1
US Nuclear Regulatory Commission**



**Nuclear Energy Institute Information Forum
San Diego, California
June 13, 2005**

Region I Topics

■ Public Notification

- Tone Alert Radios (distribution and maintenance)
 - White finding, 10 CFR 50.47 (b)(5)

■ Sirens

- Rotation sensor test failures
- Back-up power supply (August 14, 2004 blackout event)

Region I Topics

- Protective Actions
 - Invalid Release Duration
 - Scenario timing issue (1 hour not correct)
 - Green finding (PAR was correct)
 - Removal of Sheltering
 - 10 CFR 50.47 (b)(10) requires range of options
 - Only PAR was evacuation

Region I Topics

■ Procedures/Training

- EOP Change without EAL Change
 - White finding per 10 CFR 50.47(b)(4)
 - Incorrect threshold for declaring general emergency and site area emergency
- Approximately 70% of ERO failed to receive training within 12 month period required in E Plan